

Dates

Year

Name of Pool

Location

Date & Time	Initials	Free Chlorine	Total Chlorine	Combined Chlorine	pH	Total Alkalinity	Calcium Hardness	Cyanuric Acid	Chemical Use	Clarity	Flow Rate	Temperature	Comments
													<input type="checkbox"/> Chemicals added / amount <input type="checkbox"/> Make-up water added <input type="checkbox"/> Backwashed / cleaned filters <input type="checkbox"/> Vacuumed <input type="checkbox"/> Mechanical Breakdown <input type="checkbox"/> Swimmer Emergency <input type="checkbox"/> Fecal Accidents <input type="checkbox"/> Other Tests / Maintenance / Issues

Parameters	Min.	Max.	Test Frequency
Free Available Chlorine (<30°C)	0.5 ppm	5.0 ppm	At least twice daily
Free Available Chlorine (>30°C)	1.5 ppm	5.0 ppm	At least twice daily
Chlorine Cyanurate (<30°C) – Stabilized	1.0 ppm	5.0 ppm	At least twice daily
Chlorine Cyanurate (>30°C) – Stabilized	2.0 ppm	5.0 ppm	At least twice daily
Bromine (<30°C)	1.5 ppm	5.0 ppm	At least twice daily
Bromine (>30°C)	2.5 ppm	5.0 ppm	At least twice daily
Combine Chlorine	-	<1.0 ppm	At least twice daily
pH	7.2	7.8	At least twice daily
Total Alkalinity	80 ppm	120 ppm	At least Weekly
Calcium Hardness (Recommended)	180 ppm	220 ppm	Weekly
Cyanuric Acid	-	79 ppm	At least Weekly